

August 30, 2005

ZABEL ENVIRONMENTAL TECHNOLOGY
SCOTT R. GRAHAM
PO BOX 1520
CRESTWOOD KY 40014

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: ZABEL ENVIRONMENTAL TECHNOLOGY
Product Name: A100-8 & A300-8 SERIES OF EFFLUENT FILTERS
Model Number(s): A100-8x12 (800 GPD), A100-8x18 (1200 GPD), A100-8x26 (1800 GPD), A100-8x32 (2400 GPD)
A300-8x12 (800 GPD), A300-8x18 (1200 GPD), A100-8x26 (1800 GPD), A300-8x32 (2400 GPD)
Product File No: 20050644

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2010.

This approval is contingent upon compliance with the following stipulation(s):

- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- This product may only be installed in the outlet tee baffle of septic tanks or compartments that have a maximum daily flow rate of no more than; 800 gallons per day for models A100-8x12 and A300-8x12, 1200 gallons per day for models A100-8x18 and A300-8x18, 1800 gallons per day for models A100-8x26 and A300-8x26, 2400 gallons per day for models A100-8x32 and A300-8x32.

This approval supercedes the approval issued on October 12, 2000, under product file number 20002015.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20002015.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mbeckwith@commerce.state.wi.us